












## OZNACZENIA:

- |   |     |   |   |
|---|-----|---|---|
|  | A1  | — | Rubin Look LED 2600lm 20W PLX E IP44 21 840 (LUXIONA)         |
|  | A2  | — | Rubin Look LED 3300lm 25W PLX E IP44 21 840 (LUXIONA)         |
|  | B1  | — | Neptun LED 4400lm 34W PC Opal E IP65 840 (LUXIONA)            |
|  | C1  | — | Bey N LED O 2500lm 29W E IP44 34 840 (LUXIONA)                |
|  | D1  | — | X-Mall K9 LED 1300lm 10W PLX E IP44 24 840 (LUXIONA)          |
|  | AW1 | — | RNO 3W 3h AT SE (LUXIONA)                                     |
|  | AW2 | — | RNC 1W 3h AT SE (LUXIONA)                                     |
|  | EW1 | — | 1-siloma typ IFB LED 1,2W 3h AT SA (LUXIONA) (praca na jasno) |
|  | EW2 | — | 2-siloma typ IFAR 1,2W 3h AT IP44 (praca na jasno)            |
|  |     |   | Łącznik świecznikowy IP44 z lampką                            |
|  |     |   | Łącznik schodowy IP44 z lampką                                |

UWAGA:

1. Instalację wykonać przewodem YDYp 3x1,5mm<sup>2</sup> w rurkach w RVKLn/375N pod tynkiem.

BRANŻA:	INSTALECJE ELEKTRYCZNE		
INWESTOR:	SZPITAL MIEJSKI SPECJALISTYCZNY im. G. NARUTOWICZA KRAKÓW, ul. PRĄDNICKA 35-37		
TEMAT :	Przystosowanie pomieszczeń dla potrzeb szpitali pracowników szpitala		
Tytuł: rysunku:	INSTALACJA OŚWIETLENIA Szatnia Męska		Rys. nr : <b>E3</b>
Opracował:	mgr inż. J. Gawlik upr nr : 48-Km/74		Skala : 1:100 Data: XII.2015r